

Annual Drinking Water Quality Report for 2019
Town of Ridgeway Water Systems
410 West Ave, Medina, NY 14103
(Public Water Supply ID#NY361221, 3630044)

May 2020

INTRODUCTION

To comply with State regulations, Town of Ridgeway, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that in 2019 our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact John Olinger, Water Superintendent, at 585-798-3680. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled town board meetings. The meetings are held on the third Monday of every month at the Ridgeway Town Hall, 410 West Ave, Medina, NY 14103 at 7:00pm.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 3600 people through 1200 service connections. Our water source is located west branch of the Niagara River. The treatment plant uses pre-chlorination, coagulation, rapid mix, flocculation, sedimentation, and filtration processes to ensure the quality of the water. The NCWD also uses chlorination for disinfection. The water treatment plant has been approved as a direct filtration plant; however, water is treated using conventional filtration including all of the processes described above. In addition, fluoride and a corrosion inhibitor are added to the potable water prior to distribution.

The New York State Department of Health recently completed a draft Source Water Assessment of the **raw water source** under the State's Source Water Assessment Program (SWAP). The purpose of this program is to compile, organize, and evaluate information regarding possible and actual threats to the quality of public water supply (PWS) sources. It is important to note that source water assessment reports estimate the **potential** for untreated drinking water sources to be impacted by contamination. These reports do not address the safety or quality of treated finished potable tap water. The Great Lakes' watershed is exceptionally large and too big for a detailed evaluation in the SWAP. General drinking water concerns for public water supplies which use these sources include: storm generated turbidity, wastewater, toxic

sediments, shipping related spills, and problems associated with exotic species (e.g. zebra mussels – intake clogging and taste and odor problems). The SWAP is based on the analysis of the contaminant inventory compiled for the drainage area deemed most likely to impact drinking water quality at this public water supply raw water intake. This assessment found an elevated susceptibility to contamination for this source of drinking water. The amount of agricultural lands in the assessment area results in elevated potential for protozoa and pesticides contamination. There is also a high density of sanitary wastewater discharges, which results in elevated susceptibility for numerous contaminant categories. Non-sanitary wastewater could also impact source water quality. There is also noteworthy contamination susceptibility associated with other discrete contaminant sources, and these facility types include: Mines and Resources Conservation and Recovery Act (RCRA) facilities. If you have any questions about the States Source Water Assessment Program, please contact Ronald Gwozdek, Principal Public Health Engineer, Niagara County Department of Health at (716) 439-7452.

FACTS AND FIGURES

The Town of Ridgeway water system serves 3600 people through 1200 service connections. The total water produced in 2019 was 63,239,080 million gallons. The total water purchased in 2019 was 79,156,680 million gallons. This leaves an unaccounted for a total of 15,917,600 million gallons. This water was used to flush mains, fight fires, and leakage. In 2019, water customers were charged \$5.25 per 1,000 gallons of water through 6/30/2019 and charged \$5.90 per 1,000 gallons from 7/1/2019 through 12/31/2019.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: microbiological contaminants, radioactive contaminants, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, synthetic organic compounds, trihalomethanes, haloacetic acids, and disinfection byproducts. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one-year-old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (800-426-4791) or the Niagara County Health Department at (716) 439-7430.

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg. / Max.) (Range)	Unit of Measurement	MCLG	Regulatory Limit	Likely Source of Contamination
Inorganic Contaminants							
Barium	No	2/19	0.021	mg/L	2.00	MCL=2.00	Discharge of drilling wastes and from metal refineries; Erosion of natural deposits.
Copper ¹ (in distribution system)	No	6/17-9/17	0.136 (0.01-0.2)	mg/L	1.3	AL=1.3	Corrosion of galvanized pipes; Erosion of natural deposits.

Table 1: Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg. / Max.) (Range)	Unit of Measurement	MCLG	Regulatory Limit	Likely Source of Contamination
Fluoride	No	1/19-12/19	0.68 (0.5 - 0.8)	mg/L	N/A	MCL=2.2	Erosion of natural deposits; Water additive that promotes strong teeth
Lead ¹ (in distribution system)	No	6/17 - 9/17	6.6 (<1.0 - 12.3)	ug/L	0	AL=15	Corrosion of household plumbing systems; Erosion of natural deposits.
Total Organic Carbon	No	1/19 - 12/19	2.2 (2.00 - 2.47)	mg/L	NA	TT	Naturally present in the Environment.
Sodium	No	2/19	12.3	mg/L	N/A	AL=20	Erosion of natural deposits. Use of road salt, discharges from water softeners.
Entry Point Chlorine Residual	No	1/19 - 12/19	1.15 (0.90 - 1.35)	mg/L	MRDL 4.0	MRDLG 4.0	Added for disinfection.
Entry Point ² Turbidity	No	1/19 - 12/19	0.02 (0.01 - 0.18)	NTU	N/A	0.3 NTU	Soil runoff
Entry Point ² Turbidity	No	1/19 - 12/19	100% of samples less than 0.3 NTU	NTU	N/A	TT = 95% of samples < 0.3 NTU	Soil runoff
Radioactive Contaminants							
Gross Alpha Particles	No	2/20	0.579	pCi/L	N/A	MCL=15	Erosion of natural deposits of certain radioactive minerals
Radium 226 and 228 combined	No	2/20	0.343	pCi/L	N/A	MCL=5	Decay of natural and man-made deposits of certain radioactive minerals.
Uranium	No	3/14	0.036	µg/L	N/A	MCL=30	Erosion of natural deposits

¹During 2017 the Niagara County Water District collected and analyzed 50 samples for lead and copper. The level presented represents the 90th percentile of the 50 sites tested. The 90th percentile is equal to or greater than 90% of the lead or copper values detected at your water system. The analysis showed concentrations below action levels for all 50 copper samples.

²Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. NCWD's highest single turbidity measurement for the year was 0.05 NTU. State regulations require that turbidity must always be below 1 NTU leaving the Water Plant and 5 NTU in the distribution system. The regulations require that 95% of the turbidity samples collected have measurements below 0.3 NTU. All samples collected in 2019 were below the treatment technique level.

TOWN OF RIDGEWAY WATER DISTRICT 1

Town of Ridgeway has not exceeded the MCL for total coliform during the 2019 reporting period.

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg.) (Range)	Unit of Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Microbiological Contaminants¹							
Chlorine Residual	No	1/19 - 12/19	0.56 (0.29 – 1.01)	mg/l	MRDL 4.0	MRDLG 4.0	Added for disinfection.
Disinfection Byproducts²							
Total Trihalomethanes	No	2/19 – 11/19	60 (40-86)	µg/l	N/A	MCL=80	By-product of drinking water chlorination
Total Haloacetic Acids	No	2/19 – 11/19	25 (13-44)	µg/l	N/A	MCL=60	By-product of drinking water chlorination
<p>¹Turbidity is a measure of the cloudiness of the water. We test is because it is a good indicator of the effectiveness of our filtration system. State regulations require that average monthly turbidity must always be below 1 NTU leaving the Water Plant and 5 NTU in the distribution system.</p> <p>²Results for Total Trihalomethanes (TTHMs) and Total Haloacetic Acids (HAA5s) are reported as the highest locational running annual average. The range of detection is shown below the average</p>							

TOWN OF RIDGEWAY WATER DISTRICT 1A

Town of Ridgeway has not exceeded the MCL for total coliform during the 2019 reporting period.

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg.) (Range)	Unit of Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Microbiological Contaminants¹							
Chlorine Residual	No	1/19 - 12/19	0.32 (0.26 – 0.65)	mg/l	MRDL 4.0	MRDLG 4.0	Added for disinfection.
Disinfection Byproducts²							
Total Trihalomethanes	No	2/19 – 11/19	53	µg/l	N/A	MCL=80	By-product of drinking water chlorination
Total Haloacetic Acids	No	2/19 – 11/19	13	µg/l	N/A	MCL=60	By-product of drinking water chlorination
<p>¹Turbidity is a measure of the cloudiness of the water. We test is because it is a good indicator of the effectiveness of our filtration system. State regulations require that average monthly turbidity must always be below 1 NTU leaving the Water Plant and 5 NTU in the distribution system.</p> <p>²Results for Total Trihalomethanes (TTHMs) and Total Haloacetic Acids (HAA5s) are reported as the highest locational running annual average. The range of detection is shown below the average.</p>							

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Level 1 Assessment: A Level 1 assessment is an evaluation of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is an evaluation of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picograms per liter (pg/l): Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We are proud that your drinking water meets or exceeds all federal and state requirements. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by New York State. It should be noted that the action level for lead was not exceeded in the 50 samples collected in 2017. However, we provide the following information on lead in drinking water for those concerned:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Niagara County Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2019, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. Fluoride is added to your water by the NCWD before it is delivered to us. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, NCWD monitor fluoride levels on a daily basis to make sure fluoride is maintained at a target level of 0.7 mg/l. During 2019 monitoring showed that fluoride levels in your water were within 0.2 mg/l of the target for 100% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

SYSTEM IMPROVEMENTS

In 2019, the Town of Ridgeway continued monitoring of equipment with vigorous operation and maintenance programs. Improvements completed through our operation and maintenance programs are critical in maintaining the quality of finished water. Construction has begun on WD#14, which includes Culvert Road from portage Road to Porter Road and continue north to Route 104 and Porter Road east toward Knowlesville Road. The proposed WD#15, which will include South Countyline road, south of Route 104 is still in the planning stages. These improvements facilitate continuing efforts to maintain a safe and dependable water supply.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office at 585-798-3680, if you have questions.

BILLING INFORMATION

You can plan on receiving your quarterly bills around the 1st of the month in January, April, July and October with payment due at the end of that month. Please plan so that you can make your payment in a timely manner and avoid the penalties, particularly the October bill, when all arrears and penalties are added to your property taxes with an extra \$100 penalty.

Also for your information, unpaid bills can result in having your water service turned off. There is a \$50 charge to have service restored (during regular work hours) or \$100 charge (after regular hours) after paying all arrears and penalties.